

# MERLIN RANGE

## Merlin FAB1



Standing for Fire Alarm Bypass the Merlin FAB1 can be integrated with any of the Merlin suite of products to give the operator the opportunity to temporarily bypass the gas isolation system.

With prior notice to a fire alarm test, the operator can turn the spring loaded key to the on position giving an un-interrupted gas supply for between 10 and 45 minutes. During this time the system controlling the gas will ignore shut-off signals from the buildings fire alarm system and allow factors such as heating systems to remain operational. The bypass time can be adjusted using the blue switches inside the panel. During the bypass time gas can still be shut off, pressing the emergency gas shut off button will close the gas solenoid valve.

### CONTACT US:

#### **S&S Northern Head Office**

Tel: +44(0) 1257 470 983

Fax: +44(0) 1257 471 937

[www.snsnorthern.com](http://www.snsnorthern.com)

[info@snsnorthern.com](mailto:info@snsnorthern.com)

#### **South East Division**

Tel: +44(0) 1702 291 725

Fax: +44(0) 1702 299 148

[south@snsnorthern.com](mailto:south@snsnorthern.com)