
Example Schematic 1 - Single Zone System to provide coverage for a single zone

WLD Water Sensing Cable – Suitable for use in

accessible and/or clean areas such as Comms Rooms

or at the base of Kitchen units in Tea points etc.



WLD Single Zone Alarm Panel, complete with audible, visual alarm, BMS and/or remote equipment interface via volt free relays "Leak" and "Fault" Common and a further zone specific "Leak" alarm volt free relay.

Alarm Panel capable of monitoring a maximum of 100m of Sensing equipment.

Hold Down Clips

Female

Connector



DRAWING TITLE:

LEAK DETECTION SCHEMATIC

Termination

PROJECT NAME:

QUOTE NUMBER:

DRAWING REVISION:

DATE:

21/10/2022

DRAWING BY:

George Dobson

S&S Northern Ltd Barnes Wallis Way Buckshaw Village Lancashire PR7 7JN

