


Carbon Dioxide Ventilation Guide For Teachers & Lecturers



Traffic Light Indicator


Merlin CO2-X display changes colour dependent on the CO2 levels and temperature.



SAFE AIR QUALITY

HEALTHY LEVELS OF CO2

<800ppm / <23 °C




ADEQUATE AIR QUALITY

INCREASE VENTILATION

I.E. OPEN A WINDOW OR A DOOR

≥800ppm / >23 °C



POOR AIR QUALITY

FURTHER INCREASE VENTILATION

**I.E. OPEN MULTIPLE WINDOWS, DOORS &
EXTRACTION FANS (IF AVAILABLE)**

≥1000ppm / >25 °C

Gas Safety Systems

Utility Control

S&S Northern Ltd. Wallace Francis House, Barnes Wallis Way, Buckshaw Village, Lancashire, PR7 7JN T. 01257 470983 www.snsnorthern.com